



**CERTIFICATE OF COMPLIANCE
0.5 MICRON**

**Colder Products
1001 Westgate Drive
St. Paul, Minnesota 55114**

January 19, 2018

Clean Area Description	Clean Area Class	Clean Area Status
Class 8 Cleanroom	ISO 8	Operational
Class 7 Cleanroom	ISO 7	Operational
Wash/Dry Room	ISO 7	Operational
Gowning Room	ISO 7	Operational

Per the results of the particle count testing, the class is considered met if the measured particle concentration is within the limits specified per ISO 14644-1 (2015). Particle counts were sampled and reported in the cumulative mode for sizes 0.5 µm and larger at a sample volume of 1 cubic foot.

CSI Testing, Inc. certifies that the above referenced clean area has been tested and meets or exceeds the stated class conditions in accordance with ISO 14644-1 (2015). CSI Testing, Inc. makes no other warranties, stated or implied, concerning the continued performance, operation or safety in use of the clean spaces listed above.

Submitted and Certified by:

CSI Testing, Inc.



CSI Testing, Inc.
14020 23rd Avenue North • Plymouth, MN 55447
Phone: (763) 383-9535 • Fax: (763) 383-9546 • CSStesting.com

**CERTIFICATE OF COMPLIANCE
5.0 MICRON**

**Colder Products
1001 Westgate Drive
St. Paul, Minnesota 55114**

January 19, 2018

Clean Area Description	Clean Area Class	Clean Area Status
Class 8 Cleanroom	ISO 8	Operational
Class 7 Cleanroom	ISO 7	Operational
Wash/Dry Room	ISO 7	Operational
Gowning Room	ISO 7	Operational

Per the results of the particle count testing, the class is considered met if the measured particle concentration is within the limits specified per ISO 14644-1 (2015). Particle counts were sampled and reported in the cumulative mode for 5.0 µm at a sample volume of 1 cubic foot.

CSI Testing, Inc. certifies that the above referenced clean area has been tested and meets or exceeds the stated class conditions in accordance with ISO 14644-1 (2015). CSI Testing, Inc. makes no other warranties, stated or implied, concerning the continued performance, operation or safety in use of the clean spaces listed above.

Submitted and Certified by:

CSI Testing, Inc.